

CP-1000 and SP-1000 Calibration Chart

Height (in.)	Volume (Gal)	54	1,115.06	42.75	882.76	31.5	650.45
65	1,342.21	53.75	1,109.90	42.5	877.60	31.25	645.29
64.75	1,337.05	53.5	1,104.74	42.25	872.44	31	640.13
64.5	1,331.88	53.25	1,099.58	42	867.27	30.75	634.97
64.25	1,326.72	53	1,094.42	41.75	862.11	30.5	629.81
64	1,321.56	52.75	1,089.25	41.5	856.95	30.25	624.64
63.75	1,316.40	52.5	1,084.09	41.25	851.79	30	619.48
63.5	1,311.23	52.25	1,078.93	41	846.62	29.75	614.32
63.25	1,306.07	52	1,073.77	40.75	841.46	29.5	609.16
63	1,300.91	51.75	1,068.60	40.5	836.30	29.25	603.99
62.75	1,295.75	51.5	1,063.44	40.25	831.14	29	598.83
62.5	1,290.58	51.25	1,058.28	40	825.97	28.75	593.67
62.25	1,285.42	51	1,053.12	39.75	820.81	28.5	588.51
62	1,280.26	50.75	1,047.95	39.5	815.65	28.25	583.34
61.75	1,275.10	50.5	1,042.79	39.25	810.49	28	578.18
61.5	1,269.94	50.25	1,037.63	39	805.32	27.75	573.02
61.25	1,264.77	50	1,032.47	38.75	800.16	27.5	567.86
61	1,259.61	49.75	1,027.31	38.5	795.00	27.25	562.69
60.75	1,254.45	49.5	1,022.14	38.25	789.84	27	557.53
60.5	1,249.29	49.25	1,016.98	38	784.68	26.75	552.37
60.25	1,244.12	49	1,011.82	37.75	779.51	26.5	547.21
60	1,238.96	48.75	1,006.66	37.5	774.35	26.25	542.05
59.75	1,233.80	48.5	1,001.49	37.25	769.19	26	536.88
59.5	1,228.64	48.25	996.33	37	764.03	25.75	531.72
59.25	1,223.47	48	991.17	36.75	758.86	25.5	526.56
59	1,218.31	47.75	986.01	36.5	753.70	25.25	521.40
58.75	1,213.15	47.5	980.84	36.25	748.54	25	516.23
58.5	1,207.99	47.25	975.68	36	743.38	24.75	511.07
58.25	1,202.82	47	970.52	35.75	738.21	24.5	505.91
58	1,197.66	46.75	965.36	35.5	733.05	24.25	500.75
57.75	1,192.50	46.5	960.19	35.25	727.89	24	495.58
57.5	1,187.34	46.25	955.03	35	722.73	23.75	490.42
57.25	1,182.18	46	949.87	34.75	717.56	23.5	485.26
57	1,177.01	45.75	944.71	34.5	712.40	23.25	480.10
56.75	1,171.85	45.5	939.55	34.25	707.24	23	474.94
56.5	1,166.69	45.25	934.38	34	702.08	22.75	469.77
56.25	1,161.53	45	929.22	33.75	696.92	22.5	464.61
56	1,156.36	44.75	924.06	33.5	691.75	22.25	459.45
55.75	1,151.20	44.5	918.90	33.25	686.59	22	454.29
55.5	1,146.04	44.25	913.73	33	681.43	21.75	449.12
55.25	1,140.88	44	908.57	32.75	676.27	21.5	443.96
55	1,135.71	43.75	903.41	32.5	671.10	21.25	438.80
54.75	1,130.55	43.5	898.25	32.25	665.94	21	433.64
54.5	1,125.39	43.25	893.08	32	660.78	20.75	428.47
54.25	1,120.23	43	887.92	31.75	655.62	20.5	423.31

CP-1000 and SP-1000 Calibration Chart

20.25	418.15	9	185.84
20	412.99	8.75	180.68
19.75	407.82	8.5	175.52
19.5	402.66	8.25	170.36
19.25	397.50	8	165.19
19	392.34	7.75	160.03
18.75	387.18	7.5	154.87
18.5	382.01	7.25	149.71
18.25	376.85	7	144.55
18	371.69	6.75	139.38
17.75	366.53	6.5	134.22
17.5	361.36	6.25	129.06
17.25	356.20	6	123.90
17	351.04	5.75	118.73
16.75	345.88	5.5	113.57
16.5	340.71	5.25	108.41
16.25	335.55	5	103.25
16	330.39	4.75	98.08
15.75	325.23	4.5	92.92
15.5	320.06	4.25	87.76
15.25	314.90	4	82.60
15	309.74	3.75	77.44
14.75	304.58	3.5	72.27
14.5	299.42	3.25	67.11
14.25	294.25	3	61.95
14	289.09	2.75	56.79
13.75	283.93	2.5	51.62
13.5	278.77	2.25	46.46
13.25	273.60	2	41.30
13	268.44	1.75	36.14
12.75	263.28	1.5	30.97
12.5	258.12	1.25	25.81
12.25	252.95	1	20.65
12	247.79	0.75	15.49
11.75	242.63	0.5	10.32
11.5	237.47	0.25	5.16
11.25	232.31	0	0.00
11	227.14		
10.75	221.98		
10.5	216.82		
10.25	211.66		
10	206.49		
9.75	201.33		
9.5	196.17		
9.25	191.01		